



# MORRISTOWN UTILITY SYSTEMS

1833 Walters Drive

P. O. Box 667

Morristown, TN 37815

Phone: (423) 317-6316

Fax: (423) 586-1241

## **Morristown Utility Systems Backflow Prevention Requirements**

- Domestic backflow preventer type required is: Reduced Pressure Backflow Preventers
- Domestic backflow preventer location is: preferably inside
- Fire sprinkler backflow preventer type required is: minimum required on a Class 1, 2, or 3 Fire Protection System is a Double Check Detector Assembly: Please note - there are "special conditions" where a Reduced Pressure Detector Assembly is required on a fire sprinkler line. If there are any questions please refer to the Morristown Utility Systems "Fire Sprinkler System Backflow Protection Policy" which can be obtained by contacting Morristown Utility Systems.
- Fire sprinkler backflow preventer location is: preferably inside
- Irrigation water backflow preventer type required is: minimum required is (1) Reduced Pressure Backflow Preventer
- Irrigation water backflow prevention location is: preferably inside
- Water meter location is: outside at property line
- All devices used for backflow prevention must be approved by the State of Tennessee along with Morristown Utility Systems. This list is available through the Morristown Water Systems Operation Office.